

## **COMPRESSED AIR RECEIVERS**

- ☐ Is every receiver equipped with a pressure gauge and with one or more automatic, spring-loaded safety valves?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Is the total relieving capacity of the safety valve capable of preventing pressure in the receiver from exceeding the maximum allowable working pressure of the receiver by more than 10 percent or 3 psi, whichever is greater?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Is every air receiver over 5 cubic feet in volume provided with a drainpipe and valve at the lowest point for the removal of accumulated oil and water?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are compressed air receivers periodically drained of moisture and oil?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Are all safety valves tested frequently and at regular intervals to determine whether they are in good operating condition?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Is there a current operating permit for compressed air receivers, 5 cubic feet or more in volume, issued by the Boiler and Elevator Branch of HIOSH?

**Action to be Taken**

**Assigned To:**

---

---

- ☐ Is the inlet of air receivers and piping systems kept free of accumulated oil and carbonaceous materials?

**Action to be Taken**

**Assigned To:**

---

---